



ELECTRICAL REMOVAL NOTES:

- 1/ DISCONNECT AND SAFE-OFF THE 277V LIGHTING FEEDS TO THE LIGHT STANDARDS IN PARKING LOT #2 (ALL LIGHTS IN PARKING LOT #1 TO REMAIN IN SERVICE).
- 2/ DISCONNECT AND REMOVE THE LIGHT FIXTURES FROM THE TWO LIGHT STANDARDS IN PARKING LOT #2 (POLES AND BASES TO REMAIN).
- 3/ LOCATE AND EXPOSE EXISTING CONDUITS IN THE AREA OF CAMERA # 2. CUT BACK CONDUITS. SEAL AND PROTECT CONDUIT ENDS TO ALLOW REUSE AFTER THE INSTALLATION OF NEW HANDHOLES.
- 4/ LOCATE AND EXPOSE EXISTING CONDUIT EXITING THE B315 FOUNDATION A SUFFICIENT DISTANCE FROM THE BUILDING TO ALLOW THE INSTALLATION OF A NEW HANDHOLE OVER THE EXISTING CONDUIT. (THE CONDUIT CONTAINS THE 480V FEED TO THE EXIT GATE WHICH MUST REMAIN IN SERVICE UNTIL THE NEW EXIT GATE IS OPERATIONAL.)
- 5/ LOCATE AND EXPOSE THE EXISTING CONDUITS EXITING THE B315 FOUNDATION A SUFFICIENT DISTANCE FROM THE BUILDING TO ALLOW INSTALLATION OF NEW HANDHOLES OVER THE EXISTING CONDUITS.
- 6/ REMOVE GATE PUSH BUTTON OPERATOR SWITCH AND ASSOCIATED BASE INCLUDING CONDUIT POST AND CONCRETE BASE. REMOVE ADJACENT CONDUIT STUB-UPS AND ON-GRADE CONNECTION BOX. (COORDINATE THIS REMOVAL WITH THE NEW GATE INSTALLATION.)
- 7/ DISCONNECT AND REMOVE THE GATE MOTOR SAFETY SWITCH, GATE MOTOR OPERATOR ASSEMBLY, AND QTY 4 IR DETECTORS. TURN GATE OPERATOR EQUIPMENT OVER TO THE GOVERNMENT. (COORDINATE THIS REMOVAL WITH THE NEW GATE INSTALLATION.)

SEE SHEET E901 FOR LEGEND

REV	DATE	DESCRIPTION	CHECK	APRVD
UNITED STATES DEPARTMENT OF TRANSPORTATION FEDERAL AVIATION ADMINISTRATION WILLIAM J. HUGHES TECHNICAL CENTER ATLANTIC CITY INT'L AIRPORT, N.J. 08405				
REPLACEMENT OF OUTBOUND GATES				315
OUTBOUND GATE ELECTRICAL DEMOLITION PLAN				
REVIEWED BY	SUBMITTED BY	DATE	APPROVED BY	DATE
	PETE SARACENI, TS	3/26/07	DAVE DANDO, SUPV	3/26/07
DESIGN: OLSEN D	ISSUED BY:	DATE: 05/08/07	JCN:	
DRAWN: FOSTER J	FACILITY SERVICES & ENGINEERING DIVISION	DRAWING NO.	SHEET #	
CHECK:	ACX-040	135999-E001	9	OF 13